MORRISVILLE WATER & LIGHT GUIDE FOR ELECTRIC SERVICE LINE EXTENSIONS

WELCOME TO MORRISVILLE WATER & LIGHT DEPARTMENT Our Application Process is Outlined Below

- 1. Complete the Application for New Electric Service or Upgrade to Existing Service, including Load Data Sheet for any service over 200 amps.
- 2. A site visit may be required prior to an estimate being created.
- 3. Pay the \$250 estimate in the form of cash, check or money order (no credit cards) to secure work by the line crew.
- 4. Complete the Application for Establishment of Utility Service(s). This ensures your meter will be read and you will be billed monthly. Joint customers must complete that section on the application.
- 5. Bring your photo ID to our office so we can copy it (or else provide us a notarized copy). Joint customers must also bring their photo ID in person.
- 6. Pay either a deposit (\$204) or provide a credit reference on the account. The credit reference must be from a bank you've had an account with for one year (form included), or another utility you've had an account with for two years. If you currently have an account in good standing with us, you can use that in lieu of the deposit or credit reference requirement (provided it has been active for at least two years).
- 7. After receipt of the paperwork, an estimate will be calculated. This will need to be paid prior to any linework starting.

Introduction

This guide is intended to provide general information to a Customer, Contractor or Developer making application for a line extension or line relocation in the Morrisville Water & Light service territory. It includes information regarding payment terms, easement and right-of- way requirements, basic design and siting requirements for both overhead and underground construction and the appeal process in the event of a dispute related to the proposed line extension. Please contact Morrisville Water & Light at 802-888-3348 if there are any questions.

Morrisville Water & Light (MWL) will consider applicants preferences in the design of the line extension, however it will not approve line extension locations that will result in additional maintenance problems or delay restoration time in the event of power outages. The design and siting of electric line extensions or relocation of lines will consider: maintenance and reliability; worker and public safety; aesthetics; cost; customer, landowner and municipal preference; and environmental and land use implications. MWL will provide relevant information in writing, with respect to off-grid electric generation solutions and options upon an applicant's request.

An applicant may contact the Vermont Department of Public Service Consumer Affairs Division at: Vermont Department of Public Service, 112 State Street, Drawer 20, Montpelier, VT 05620-2601. 1-800-734-8390 or consumer@state.vt.us, or refer the matter to the Public Service Board, 112 State Street, Drawer 20 Montpelier, VT 05620 in the event of a dispute with reference to the proposed line extension. A copy of PSB Rule 5.600 - Electric Service Extension Policy is attached.

General Information

The following are general requirements for line extensions. Each line extension will be considered individually and the job specifications for each application will be the basis for construction.

Applying for a Line Extension

An applicant must complete and submit a written application form to MWL along with a \$250 Application Fee for the engineering, design and cost estimate for a line extension. This is a non refundable fee; however it will be credited toward the total cost of the line extension if the extension is constructed. MWL will provide a design and cost estimate to the applicant along with any easement or trimming requirements. This fee normally will be waived if the work does <u>not</u> involve extending primary power or installing poles.

General Guidelines for Overhead Primary Construction

MWL will design the line and provide an estimated cost of construction. MWL will apply for any local or State permits required to build the line within a Town or State highway right-of- way. If special federal, state or local permits, such as "Act 250" permits or particular town permits, or condemnation are required for the construction of the line the applicant shall pay the cost associated with obtaining the permit.

Poles shall be located adjacent to a roadway which is suitably maintained to permit MWL maintenance vehicles access in all weather conditions. Construction of the line extension will not begin until a road is constructed.

An applicant shall provide a suitable easement for construction on the applicant's property and is responsible to obtain easements on other property, if required for the construction of the line extension. The applicant shall bear any cost for obtaining such easements.

The applicant is responsible for providing all necessary trimming to MWL specifications for an overhead line extension. This includes the applicant's property, as well as any other property where trimming is needed for the construction of the line. If it becomes necessary for MWL to provide the trimming, the applicant shall bear any cost associated with the work.

Telephone, cable and electric will normally be on the same pole. If the applicant is going to have either telephone or cable, the applicant must separately contact the respective company to determine the charges and requirements for each.

General Guidelines for Underground Primary Construction

MWL will design the line, provide an estimate of MWL costs for its work, provide its construction standards and a list of materials the applicant is responsible for providing for construction of the line. Each job will

The applicant is responsible for all the trenching and backfilling to MWL specifications. MWL <u>must</u> inspect the trench before it is backfilled. Failure to notify MWL for an inspection may result in reopening the trench.

The applicant is responsible for providing and installing conduit(s) for the underground primary line including the conduit to reach the top of the pole. MWL will install the conduit on the pole.

Pad transformers and junction boxes will be located within 18' of a roadway which is suitably maintained to permit MWL vehicles access to the equipment any time during the year.

An applicant shall provide a suitable easement for construction on the applicant's property and is responsible to obtain easements on other property if required for the construction of the line extension.

The installation of underground primary is weather sensitive and MWL generally will not install underground cable between the period November 15 to April 15.

Cost and Payment

The applicant is required to pay MWL the estimated cost of construction prior to the start of construction. The job will be billed at actual cost and if the actual cost exceeds the estimate, the customer agrees to pay the difference. If the actual cost is less than the estimate, MWL will refund the balance to the customer.

Each new residential single family residence or individual dwelling unit is entitled to a credit equal to the cost of a service drop as defined in PSB Rule 5.600.

Line Construction Option

An applicant is entitled to contract with a private contractor for the construction of a routine line extension or relocation. All construction and materials shall be in accordance with MWL's distribution standards and specifications which will be provided to the contractor. MWL will design or approve the design of the line and the construction shall be subject to inspection and monitoring by MWL at the applicant's expense. MWL will make all the primary cable terminations and overhead connections to its system. The contractor must notify MWL of the construction commencement date, specifications and standards. The contractor must provide a satisfactory certificate of insurance to MWL prior to commencing any construction. The applicant will be charged for any MWL work including, but not limited to, engineering, monitoring, inspections, cable terminations and overhead connections. The line ownership and responsibility for maintenance of the line extension or relocation shall transfer to MWL at the time the line is energized.

MWL will not connect any contractor built line extension or relocation which does not meet the above requirements.

Relocations of existing lines

MWL will consider the relocation of an existing line upon receiving a written application from a customer. The request will be reviewed to determine the feasibility and if the proposed relocation site is acceptable. All costs associated with the relocation shall be paid by the applicant. The same criteria discussed in electric service extensions shall also apply to service relocations.

Customer-Owned Primary Lines

As a general rule, residential customers shall not own primary lines (overhead or underground) that are installed after October 1, 2008. In certain circumstances where MWL and a customer agree that such ownership would be appropriate, MWL and the customer shall petition the Board for a waiver of this prohibition. Any such petition shall address the issue of underground damage prevention with respect to the facilities to be owned by the customer. MWL shall not be responsible for such customer-owned line nor shall MWL be liable for any claims by any persons relating in any way to the customer-owned line.

5.600. ELECTRIC SERVICE EXTENSION POLICY

5.601. Purpose

This Rule implements the legislative mandate of 30 V.S.A. § 209(b)(1)(B).

5.602. Applicability

Effective: October 1, 2008

This Electric Service Extension Policy shall apply to all single-phase and multiphase distribution service extensions by Vermont electric utilities (as defined by 30 V.S.A. §§ 201 and 203). All such utilities shall revise their tariffs to conform to these rules. These rules shall supercede any utility tariff provision determined to conflict with these rules.

5.603. Definitions

- (a) Application fee: the fee paid by the line extension customer at the time the customer submits a written application for a line extension. The phrase "application fee" is intended to include any "engineering fee." The application fee shall not exceed \$250, unless a higher fee is specified in the utility's line extension tariff. If applicable, such a higher fee shall be based on an average of all the costs incurred by the utility for all line extensions constructed in a test year. The application fee shall be credited to the customer against the total cost of the line extension if the extension is constructed.
- **(b)** Contributions-In-Aid-Of-Construction: the monetary contributions by a customer requesting service to an electric utility to design, furnish, place and construct such primary and secondary service extensions as are necessary to render the service requested.
- (c) Conduit: the pipe that encloses and protects electric conductors in underground power installations, including necessary fittings and connectors.
- (d) Customer-Owned Lines: electric service lines, at either primary or secondary voltage, extending from the Delivery Point.
- (e) Delivery Point: the point at which the utility-owned facilities first connect to the customer-owned facilities. Each utility's line extension tariff shall specifically identify the typical Delivery Point for each type of electric service that it provides and shall state how the Delivery Point may be determined for specific situations in which the actual Delivery Point differs from the typical Delivery Point.
- **(f) Looped Electric Utility Service:** electric service provided to a customer from a distribution line which receives, or is capable of receiving, its electric supply from both directions of the distribution line.
- (g) Primary Line: an electric distribution line operating at greater than 600 volts.

- (i) Service Drop: includes a 100-foot overhead power line(s) from the initial customer connection with the utility's secondary facilities to the Delivery Point. The service drop is the minimum overhead secondary electrical connection and shall not include poles, primary wiring, right-of-way clearing or acquisition, trenching or backfilling, or any other cost item required to serve a new or relocated customer.
- (j) Service Extension: the electric facilities required to connect the power line existing at the time of the request for service to the customer's premises. The service extension shall include all poles, primary wiring, secondary wiring, right-of-way acquisition and clearing, trenching and backfilling, any other one-time cost items associated with service only to that new customer, and transformer(s) and meter(s) if so provided in the utility's tariff. A Service Extension shall include the reestablishment of a previously abandoned Service Extension.

5.604 Contributions-in-Aid-of-Construction for Electric Service Extensions

Upon written application of the owner of any property, or occupant with the consent of the owner, the electric utility shall furnish, place, and construct such secondary and primary service extensions as are necessary to render the service requested. The total cost of the service extension, less any credits outlined below, shall be paid by the party requesting the service extension. This requirement is subject to the following conditions/exceptions:

- (a) Line Assessment Charges: all customer charges for construction of new utility lines shall be based on the actual costs to the utility. However, a utility shall charge average costs for those elements for which average costs are specified in its tariff.
- (b) Service Drop Credit: each new single-family residence or individual dwelling unit is entitled to a credit equal to the cost of the service drop(s) as defined above. However, if the cost of a line extension is less than the cost of the service drop(s) as defined above, the amount of the service drop credit shall be the same as the cost of the extension.
- (c) Installation of Conduit: the additional material cost of installation of conduit for underground primary and secondary line extensions shall be shared equally between the customer and the utility. The cost of trenching and backfilling of the trench shall be the responsibility of the owner of the property.

5.605 Cost Recovery Period for Contributions-in-Aid-of-Construction

Whenever more than one customer is connected to a customer-fmanced line extension, total contributions-in-aid-of-construction shall be computed to yield to the utility not more than the total cost of extending or expanding service to the new customer(s), less the service drop credit(s). Amounts to be collected from new customers connecting to customer-financed lines shall be computed as follows:

(a) For a period of five (5) years from the completion of construction of a line extension, reimbursement from new customers connecting to said line to customers entitled to reimbursements shall be based upon an equal sharing of the full cost of construction of the

subject line extension, adjusted to the percentage used of that line extension to the point of connection (or other reasonable method employed by the utility to detennine the cost of the portion of the line actually used).

- (b) For a period of ten (10) years immediately following the initial five (5) year period discussed in (a) above, reimbursement to customers entitled to reimbursements shall be based upon an equal sharing of the full cost of construction of the subject line extension depreciated at a straight line rate to zero at the end of the ten (10) year period, also adjusted to the percentage of the line extension used to the point of connection (or other reasonable method employed by the utility to determine the cost of the portion of the line actually used).
- (c) For each new transaction (defined as one or more new connections at the same time and location) involving a line that is subject to contribution-in-aid-of-construction payments for new connections within the 15-year reimbursement period, an administrative fee not to exceed \$100.00 shall be retained by the utility from the total amount to be reimbursed to customers entitled to reimbursements. If the total amount of all reimbursements owed for each transaction is less than the utility's administrative fee, no reimbursements shall be collected or distributed.
- (d) All line extension reimbursements shall be paid by electric utilities to the current owners of the dwellings or structures served by line extensions that are subject to reimbursement payments for new connections, except that reimbursement payments shall be made to any customer who paid for or contributed to the costs of line extensions and who subsequently sold the dwellings or structures originally served prior to the effective date of the Board's Order of September 21, 1999, in Docket 5496.

5.606 Tax Assessments on Contributions-in-Aid-of-Construction

Customers shall be responsible for all costs of line extensions, including the actual utility tax liability from contributions-in-aid-of-construction.

5.607 Interest on Customer Funds Held by Utilities

- (a) No interest shall be paid on an initial application fee.
- (b) No interest shall be paid on funds received in advance of line extension construction and used for the purpose of ordering long lead time specialty items necessary for the subject line extension.
- (c) With the exception of items (a) & (b) above, interest shall be paid, at the rate of 1% per month, to line extension customers on funds received in advance of construction (unless returned to the customer due to perceived delays), from sixty (60) days after the payment is received by the utility to the date of the commencement of the line extension construction.

Effective: October 1, 2008

- (d) No interest shall be paid by the utility under item (c) above as a result of construction delays beyond the control of the utility.
- (e) Interest to be paid on funds received more than sixty (60) days in advance of the commencement of line extension construction may be waived by customers seeking priority status for construction at a specified time as agreed to by both the customer and the utility.

5.608 Construction Standards

- (a) Minimum Standards: All line extensions shall conform to the latest edition of the National Electrical Safety Code at a minimum; except that Cooperatives may have higher minimum standards pursuant to the requirements of the Rural Utilities Service.
- (b) Customer-Owned Lines: As a general rule, residential customers shall not own primary lines (overhead or underground) that are installed after the effective date of this rule. In certain circumstances where the utility and customer agree that such ownership would be appropriate, the utility and the customer shall petition the Board for a waiver of this prohibition. Any such petition shall address the issue of underground damage prevention with respect to the facilities to be owned by the customer. However, no such petition shall be required for a customer to extend or connect to a line already owned by that customer.
- (c) Customer Information for Line Extensions: To explain utility line extension policies adequately to its customers, all utilities shall develop, either individually or collectively, a comprehensive infolmation booklet or brochure for line extension customers that fully explains its line extension policies and their rationale. This booklet shall explain that utilities will, to the extent possible, try to accommodate individual customer line extension needs, but that no deviations will be granted that will result in significant additional maintenance problems for the utility, and additional costs resulting from the accommodation will be the responsibility of the customer.

5.609 Use of Private Contractors for Line Extensions

All electric utilities shall allow customers to hire private contractors for construction of routine distribution line extensions. Utilities shall be allowed to design and monitor the construction of these lines at customer expense.

Rule 5.600 Page 5 of 6

Effective: October 1, 2008

5.610 Appropriate Customer Payment of Contributions-in-Aid-of-Construction for **Electric Line Relocations**

For all relocated distribution lines that provide a benefit to the utility, customers who request the relocation shall reimburse electric utilities for distribution line relocations according to the following formula:

CPTAX ADJ.

New Line + PVDEP SVEXISTING

Where:

CPTAX ADJ.

Customer Payment, adjusted for any

utility tax liability

Total cost of relocating the

line today

New Line

PVDEP

Present value of any unrealized depreciation expense associated with

the existing line

Salvage Value of existing line (including

line removal costs)

SVEXISTING

5.611 Change in Presumption as to Reimbursements for Contributions-in-Aid-of-Construction

The presumption regarding reimbursements for customer-financed lines shall be changed if there is a grantee/grantor relationship between the person connecting to a customer-financed line and the person who originally paid for the line to whom a reimbursement would otherwise have been due. In such cases, no reimbursement will be collected from the connecting customer or paid by the utility to the grantor.

5.612 Considerations in the Design and Siting of Line Extensions

- (1) In determining the appropriate design and siting (e.g., whether roadside or offroad and overhead or underground) of electric distribution line extensions and relocations of line extensions, electric utilities shall consider: maintenance and reliability; worker and public safety; aesthetics; cost; customer, landowner and municipal preference; and environmental and land use implications.
- (2) When a customer requests an electric line extension, the utility shall inform the customer in writing of customer and company rights, responsibilities and options for line extensions, including but not limited to: payment terms; easement and right-of-way information; contribution-in-aid-of-construction; basic information about design, siting and location, such as overhead or underground placement, and road-side or off-road siting; and how to contact the Vermont Department of Public Service Consumer Affairs Division by toll-free phone or in writing in the event of a dispute.

Effective: October 1, 2008

5.613 Information Regarding Line Extension Alternatives

Upon request, a retail electric distribution utility shall provide relevant infoiniation in writing, preferably brochures, with respect to off-grid electric generation solutions and options.

Village of Morrisville

Water & Light Department 857 Elmore Street

TRUSTEES
Peter Bourne, Chairman
Dana Wildes
Chris Audy
Brad Limoge
Jonathan Sturges

857 Elmore Street

Morrisville, Vermont 05661-8408
(802) 888-3348

Fax: (802) 888-5911

www.mwlvt.com

MANAGER Craig Myotte

Credit Reference for Utility Service (13100)

Name of Applicant:	
Service Location:	
I authorize my financial insti regarding my currei	•
Applicant signature	Date
Banking/Credit Institutions' Name:	
Mailing Address:	
Bank Phone Number:	
Account Number:	
Account Type: Checking:	Savings:
Date account opened:	
Has account had activity in the last 12 months? Yes	No
Has this account had any returned checks due to Yes	
If yes, number of times?	
Have they had any overdrafts in the last 12 month Yes	
Bank Representative Signature & Position	

Account	#
Previou	s Owner:
Deposit	Requirement:

VILLAGE OF MORRISVILLE WATER AND LIGHT DEPARTMENT (MW&L) 857 Elmore Street Morrisville, Vermont 05661-8408

(802) 888-3348 Fax (802) 888-5911

APPLICATION FOR ESTABLISHMENT OF UTILITY SERVICE (S)

Customer's Name		
Customer's Soc. S	Sec. #	
Phone Number (Hor	ne)	(Cell)
Service Address:	Street	
		Zip
Billing address:	Name	
	City/Town	
		Zip
Current Employer		
Employer's Phone	Number	
	Soc. Sec. #	
		(Cell)
	Current Employer	
	Employer's Phone Number	
Have either of yo	ou ever had service with	MW&L? If yes,
location and when	:	Acct #
	u ever had service with	
utility? I	f yes, what utility and	when:
		Acct #
Are you: Owner _		
Landlord: Name _		

When do you want service to begin?			
Is this your main residence:			
Yes No			
If commercial, owner's name and type of business:			
Electric Heat: Yes No			
FOR SCHEDULED INTERRUPTIONS OF SERVICE(S), will there be anyone			
in this household on emergency medical life support requiring			
electricity or municipal water? No Yes. If yes,			
please fill out our Emergency Medical Condition form.			

I (We) hereby apply for utility service(s), to be			
furnished in accordance with the Village of			
Morrisville Water & Light Department's Rule and			
Regulations as filed with and approved by the			
Vermont Public Service Board and are available for			
review at the MW&L office at 857 Elmore Street,			
Morrisville, Vermont. I (we) agree to pay for such			
service(s) in accordance with the Department's			
applicable rate schedules.			
Customer Signature: Date:			
Joint Customer Signature: Date:			
FOR INTERNAL USE ONLY			
Check Harris for previous/other			
accounts			
Deposit/Credit Ref			
Terms & Conditions			
On-line access instructions Credit Card Form			
Acct. built on			

VILLAGE OF MORRISVILLE WATER & LIGHT DEPARTMENT

857 ELMORE STREET P.O. BOX 460 MORRISVILLE, VT 05661 (802) 888-3348

APPLICATION FOR NEW ELECTRIC SERVICE OR UPGRADE TO EXISTING SERVICE

Please complete this form,	sign and return it to the office		
Applicant Name(s)			
Mailing Address	Town	State	Zip
Daytime Phone #	e # Home Phone # Cell #		
Location of Property:			
Town	Road/Street	E-911	
** Complete sketch on back road, and existing poles	k showing property lines, planned loca or provide site plan of the lot or devel	ation of the buildin opment.	g, driveway,
Type of Service:			
Residential [] Comme	rcial[] Industrial[] Farm[] Mul	ti-family [] Mobi	le Home []
Other			•
Single Phase [] Three	e Phase []		
Service to building: Ove	rhead [] Underground [] rhead [] Underground [] e [] Pedestal [] Building []	Other:	
Size of Service:			
100 amp [] 200 Amp [] Other:Amp (load she	et required if >20	Oamp)
Voltage Requested: Single Phase: 120/240 volt (3 wire) [] 120/240 volt (4 wire) [] (ı	<u>Three-Phase:</u> 120/208Y 4-wire [mobile home) 277/480Y 4-wire []]	
Other:	* (Need MWL approval for any vol	tage not listed above	e)
Non-Standard Equipment List any special equipment	: being installed (i.e. welder, electric he	eat , large load ap	pliance, etc.)
Motors over 5 H.P. (if size o	of service is 200 amp or less)		, , , , , , , , , , , , , , , , , , , ,

S	ite Sketch	
•		
		•
		, savet ev
ate Service is Needed:	-	
pplication fee: \$250 [] Date		
pplicants Signature :	Date	
	Date	

Note: This is only an application to extend service to the property/building. You must apply at Customer Service to establish an electric service account in your name before a meter will be installed.

		CUSTOMER	LOAD DAT	[A		- 1
CUSTOMER'S N	VAME	ADDRESS			TELEPHO	NE NO.
CONTRACTOR'	SNAME	ADDRESS				
ooning of or	DIVAME	WDDKF22			TELEPHO	NE NO.
ELECTRICIAN'S	SNAME	ADDRESS			TELEPHO	NE NO.
LOCATION		SERVICE AI	DDRESS			•
□PROSPECTIVE NEW (CUSTOMER		•	□PROSPEC:	TIVE INCREA	SE LOAD
•		BUILDING INF	ORMATION			
Building Use:	Expect	ed Hours of Operation		ıare Footage	Shi	ſts
Existing Service	Amps	SERVICE INFO	ORMATION olts	Phase		***
Service Desired	Amps		olts	Phase _		Wire Wire
Date Service Desired	N	umber of Existing M			New Meters	vvire
Size of Main Panel		Amps		Classification	THE PROCESS	
Metering Requirements			Load	Management?	□Ves □	No
Request Fault Current?	□No □Yes	(Submit request for CONNECTE	n) No. of DLOADS	Runs of Seconda	ary	110
Ain Conditionin	TTD TILO NA	Existing New/Increas			Existing	New/Increase
Air Conditioning Cooking Equipment	HP/TONS	***************************************	Motor Load	F	IP_·	
Heating Load	KW		Refrigeration	K	CW	
Lighting Load	KW		Storage Heat	K	CW	
Receptacles	KW .		Water Heating	K		
Miscellaneous	KW KW		Special Equip. (Welder,X-Ray, Etc)	KW	•
Total Connected	KW		Estimated Dema	ınd	KW	
Emergency Generator List all individual motors or		Yes Size	s	witch Type		
mise all musikingat motots of	er 5 HP	· · · · · · · · · · · · · · · · · · ·			·	
Single phase motors over 5 HP an Miscellaneous Motors					Use back of sheet	
This data will be used for tra	ansformer sizing	and connected load b	oilling information	for this account	. If load chang	'es
agamicanity, contact the Dis	strict Ullice.				a	,
Completed by	-				Date	
accepted by		Title			Date	
(Utility Represer	Itative)		PART VALUE VERNE VERNE BALLYON OF A CALL			
		For Utility	se Only			
District						
Circuit .	Line Name	Town		_		
resent Demand		pected Increase		Pole	/Pad Number_	
Stimated Annual Revenues		heeren Hierease	,	Expected Total	Demand	
rom:		pt		TO 4.		
O: DENGINEERING DENERGY PLANT OTHER	☐MET)		RICT SUPERINT		DENERGY SE	RVICES
	ONT UTILI	TIES ELECTRIC	C SERVICE R	EQUIREMI	ENTS DRAWIN	G #501
			_			-
Revised July 8, 1997			•			

Village of Morrisville

Water & Light Department

nd Stres Fodd Deuso, Chairman Steve Leach Brad Limoge Carl Fortune Lom Snipp

MANAGER Craig Myone

NET METERING GUIDELINES


We have received your application for a Net-Metered-Photovoltaic system. Below is the criteria required by Morrisville Water & Light's for installing a net metering project on our electric system.

MWL's requirements are as follows:

- The meter socket for the solar device <u>must</u> be installed adjacent to the existing billing meter. The billing meter may be located on the building, on a meter pedestal or on a pole. The installation requirements and material the contractor supplies will be different depending on the meter location. I have attached the standard diagram for a meter on the building. If the billing meter is located on a pedestal or pole, the contractor needs to contact MWL prior to doing any work to determine if there will be any charges from MWL to accommodate the second meter.
- 2) The meter for the solar device must be provided and installed by MWL. There will be a flat charge of \$95.25 for the installation of this meter. This billing will be made to the customer. However, if there are issues with the inspection and MWL needs to make addition visits to the site there will be additional labor charges based on actual time.
- 3) The contractor needs to make arrangements with MWL before opening the billing meter socket to install a nipple connector or make connections in the socket.
- 4) Installer's production meter can only be installed temporarily for testing the installation and shall be removed until MW&L installs the utility owned production meter.
- 5) MW&L does not accept the ConnectDER as a means of AC Disconnect between production meter and utility meter. A lockable disconnect between production meter and utility meter which provides a visible air gap is required.
- 6) Installer shall schedule in advance a final inspection with MWL personnel at which time the utility provided production meter will be installed.
- 7) Any solar installation 10 kw or greater may require a larger transformer to be installed. Any make ready work provided by the utility requires a \$250.00 engineering/application fee. The resulting estimate must be paid before Morrisville begins the job. After the work is completed MWL will bill or refund according to actual cost.

If you have any questions, please contact David Heller at 802-888-3348 or dheller@mwlvt.com.

CLEARANCE BETWEEN ELECTRIC METERS L.P. OR NATURAL GAS EQUIPMENT



NOTES:

1) NATIONAL GAS CODES REFER TO CLEARANCE FROM SOURCES OF IGNITION FOR GAS METERS, SERVICE REGULATORS, RELIEF VALVES, FILL CONNECTIONS, VENTS DRAINS AND OTHER COMPONENTS.
ELECTRIC METERS, DEPENDING ON FEATURES OF THEIR DESIGNS, MAY BE SOURCES OF IGNITION.

2) THIS STANDARD IS INTENDED TO SERVE AS A GUILDELINE IN SPECIFYING THE POINT OF ELECTRIC SERVICE WHERE LIQUID PETROLEUM OR NATURAL GAS INSTALLATIONS ARE PRESENT. THE REQUIREMENTS IN THE NFPA GAS CODES ARE INTENDED AS FIRE-PREVENTATIVE MEASURES, NOT AS ELECTRICAL REQUIREMENTS OR PERSONAL PROTECTION MEASURES. IN THIS APPLICATION WE ARE AVOIDING A GAS CODE VIOLATION WHEN LOCATING, OR RELOCATING, THE ELECTRIC SERVICE EQUIPMENT, AFTER THE GAS EQUIPMENT HAS BEEN INSTALLED.


3) MAINTAIN THE FOLLOWING CLEARANCES:
A) INSIDE INSTALLATIONS SHOULD MAINTAIN CLEARANCE OF NOT LESS THAN: 3.0 FT.
B) OUTSIDE INSTALLATIONS SHOULD MAINTAIN CLEARANCE SHOWN ON FIGURE SHOWN ABOVE.
C) AN LP GAS REGULATOR, MOUNTED ON THE BUILDING SHOULD MAINTAIN A CLEARANCE OF 5.0 FT.

1. NFPA-54 (NATIONAL FUEL GAS CODE), NFPA-58 (L.P. GASES), AND 49CFR SUBPART H (FOR NATURAL GAS).

ELECTRIC SERVICE REQUIREMENTS

DRAWN: LAW	DAT	E: <i>01-01-07</i>
APPRVD: 2955	DAT	E: <i>01-19-07</i>
DRAWING No.:	401	PAGE: 1
DATA BASE NO	: OT	W01000c

TYPICAL METER PEDESTAL




Meter sockets must be visible from the nearest roadway.

Morrisville Water & Light ELECTRIC SERVICE REQUIREMENTS


	DRAWN:	DAT	E:
	APPRVD: YES	DAT	E:
	DRAWING No.:		PAGE:
į	DATA BASE No.	:	

OVERHEAD SERVICE




MORRISVILLE WATER &LIGHT ELECTRIC SERVICE REQUIREMENTS

DRAWING No.:	PAGE: 1
APPRVD: YES	DATE: 05-18-06
DRAWN: JAT	DATE: 35-18-36



TYPICAL TEMPORARY SERVICE



- A. A minimum of 18' clearance is required above all roads, streets, nonresidential driveways, parking lots and other land traversed by vehicles.
- B. A minimum #6 copper ground cable must be connected in the meter socket, to its own ground terminal
- C. Temporary service is limited to a six month time period unless extension is approved by MWL.

Village of Morrisville

Water & Light Department 857 Elmore Street

857 Elmore Street Morrisville, Vermont 05661-8408 (802) 888-3348 Fax: (802) 888-5911 www.mwlvt.com

THE	FOLLOWIN	G IS A LIST OF MATERIALS THAT ARE TO BE SUPPLIED BY THE CUSTOMER:
		Ground Rod
	disimus and a	Ground Rod Clamps
		#2 Strand Copper
•	-	3" PVC Pipe .
	W	3" PVC Coupling
-	•	3" PVC 90° Long Sweep
-		3" PVC Frost Joint
-		Fiberglass Pad - 32 X 36 X 32
-		Fiberglass Junction Box (either "Highline model fcs3353ga or Nordic ND-150")
		1/0 15KV Primary cable (220 MIL) with jacket neutral
		2" PVC Pipe - Only covers distance from fiberglass pad to meter socket.
	·····	2" PVC Coupling
_		2" PVC 90° Long Sweep

2" PVC Frost Joint

6 x 6 x 12 PT

2 x 6 x 12 PT

Marking Tape



Okoguard® URO-J

15kV Underground Primary Distribution Cable-Jacketed Red Identification Stripes

Filled Strand Aluminum Conductor/105°C Rating 100% and 133% Insulation Levels

THE DEPT OF THE PARTY INSUL

- A Conductor Stranded Aluminum with Filled Strand - Water Swellable Power
- B Strand Screen Extruded Semiconducting EPR
- C Insulation Okoguard EPR
- D Insulation Screen Extruded Semiconducting EPR
- F Encapsulating Jacket-Okolene with Extruded ID Stripes & NESC lightning bolt

Insulation

Okoguard is Okonite's registered trade name for its exclusive ethylene-propylene rubber (EPR) based, thermosetting compound, whose optimum balance of electrical and physical properties is unequaled in other solid dielectrics. Okoguard insulation, with the distinctive red color and a totally integrated EPR system, provides the optimum balance of electrical and physical properties for long, problem free service.

The triple tandem extrusion of the screens with the insulation provides optimum electrical characteristics.

The compressed conductors are filled with water swellable powder. This construction slows the migration of water through the strands in the event of a mechanical dig-in followed by external exposure to water. An insulation screen of ethylene-propylene rubber is extruded over the insulation. The copper concentric wires are uniformly spaced around the insulation screen. The overall polyethylene jacket provides protection against mechanical damage and corrosion.

Product identification is provided through the use of three red stripes placed 120° apart in the black jacket, with an NESC lightning bolt.

Applications

Okoguard URO-J cables provide maximum circuit longevity in underground residential distribution systems. They can be buried directly or installed in underground ducts or conduits.

Specifications

Central Conductor: Aluminum per ASTM B-609, Class B stranded per B-231.

Filled Strand: Water swellable powder meets or exceeds ICEA T-31-610 water penetration resistance and ANSI/NEMA class A connectorability requirements.

Conductor Screen: Extruded semiconucting ethylene-propylene rubber meets or exceeds the requirements of ICEA S-94-649 and AEIC CS8.


Insulation: Extruded Okoguard meets or exceeds the requirements of ICEA S-94-649 and AEIC CS8.

Insulation Screen: Extruded semiconducting ethylene-propylene rubber meets or exceeds the requirements of ICEA S-94-649 and AEIC CS8.

Concentric Conductor: Bare copper wires. Jacket: Black Okolene with red extruded stripes meets or exceeds the requirements of ICEA S-94-649 for polyethylene jackets.

Product Features

- ⁹ Triple tandem extruded, all EPR system.
- Okoguard cables meet or exceed NEMA/ICEA and RUS 7CFR 1728.204 standards
- * 105°C continuous operating temperature.
- * 140°C emergency rating.
- * 250°C short circuit rating.
- · Excellent corona resistance.
- Low dielectric constant and power factor.
- Screens are clean stripping.
- Exceptional resistance to "treeing".
- Filled strand conductor.
- Moisture resistant.
- 3 Overall jacket provides extended life.
- Excellent resistance to most chemicals.
- Can be listed by UL as Type MV-90 on special orders.
- Cable listed by CSA to C68.5 on special orders.
- Design Options:
 Additional conductor sizes
 Copper central conductor
 Copper flat strap concentric neutral
 Product identification via colored jackets.
 Semiconducting jackets.
- Improved Temperature Rating.
 Okoguard insulation system has been tested and qualified for operation at 105°C continuous and 140°C emergency operating temperature.
- Minimum installation temperature of -40°C.













SINGLE PHASE TRANSFORMER INSTALLATION finish grade 12° crushed #2 copper stone Ground rod and clamp B' Groundrod and clamp PVC plpes start of run end of Continuous run #2 copper 3' PVC with leave 6' tail in vault 36' radius sweep Ground rod and clamp FACING Fiberglass vault DRIVEWAY Front of vault 3'-7' 2' PVC secondary to pedestal use only 36 radius sweep

MORRISVILLE WATER &LIGHT ELECTRIC SERVICE REQUIREMENTS

DRAWN: JAT	DATE: 05-18-06
0.77	
APPRVD: YES	DATE: 05-18-06
DRAWING No.	PAGE: 1
DATA BASE No	.1



SINGLE PHASE JUNCTION & TRANSFORMER INSTALLATION



MORRISVILLE WATER &LIGHT ELECTRIC SERVICE REQUIREMENTS

	DRAWN: JAT	DATE: 05-18-06
	APPRVDI YES	DATE: 05-18-06
	DRAWING No.:	PAGE: 1
	DATA BASE No.	